

Date	MW ID#	Parameter	Result	Limit
03/31/2017	MWC-15	Barium	20	2.0
06/30/2017	MWC-30	Barium	73	2.0
06/30/20177	MWC-15	Barium	20	2.0

Observation: The only exceedance is MWC-30, 9/30/2017, 2.3 mg/L. The unit (ug/L) is incorrect in the WAFR database and on the monitoring report. The unit should be mg/L as stated in the facility permit. This will be corrected as required.

Maxville: In-Compliance

DMRs review period	From 01/01/16 to 12/31/17
Any exceedances?	Yes
All monitoring wells accessible, secured & locked?	Yes

Observation: A review of the Groundwater Monitoring Reports revealed the following exceedances:

Date	MW ID#	Parameter	Result	Limit
03/31/2016	MWC-2	pH	3.81	6.5-8.5
03/31/2016	MWC-2	Color	26	15
03/30/2016	MWC-2	Iron	13000	300
03/31/2016	MWC-3	pH	3.07	6.5-8.5
03/31/2016	MWC-3	Iron	8200	300
03/31/2016	MWC-5	pH	5.79	6.5-8.5
03/31/2016	MWC-5	Iron	1100	300
03/31/2016	MWC-8	pH	4.27	6.5-8.5
03/31/2016	MWC-8	Iron	350	300
06/31/2016	MWC-2	pH	3.62	6.5-8.5