

Date	MW ID#	Parameter	Result	Limit
06/31/2016	MWC-2	Iron	16000	300
06/31/2016	MWC-3	pH	3.86	6.5-8.5
06/31/2016	MWC-3	Iron	23000	300
06/31/2016	MWC-5	pH	5.4	6.5-8.5
06/31/2016	MWC-5	Iron	1200	300
06/31/2016	MWC-8	pH	4.79	6.5-8.5
06/31/2016	MWC-8	Iron	1800	300
09/31/2016	MWC-2	pH	3.7	6.5-8.5
09/31/2016	MWC-2	Iron	17000	300
09/31/2016	MWC-3	pH	3.9	6.5-8.5
09/31/2016	MWC-3	Iron	22000	300
09/31/2016	MWC-5	pH	5.3	6.5-8.5
09/31/2016	MWC-5	Iron	980	300
09/31/2016	MWC-8	pH	4.3	6.5-8.5
09/31/2016	MWC-8	Iron	1300	300
12/31/2016	MWC-2	pH	4.4	6.5-8.5
12/31/2016	MWC-2	Iron	20000	300
12/31/2016	MWC-3	pH	3.9	6.5-8.5
12/31/2016	MWC-3	Iron	7100	300
12/31/2016	MWC-5	Color	21	15
12/31/2016	MWC-5	Iron	470	300
12/31/2016	MWC-8	pH	5.5	6.5-8.5
12/31/2016	MWC-8	Iron	1200	300
03/31/2017	MWC-2	pH	3.58	6.5-8.5
03/31/2017	MWC-2	Iron	19000	300