

Date	MW ID#	Parameter	Result	Limit
09/30/2016	MWC-4	pH	4.1	6.5-8.5
09/30/2016	MWC-3w	Iron	1.2	0.3
09/30/2016	MWC-3w	pH	4.9	6.5-8.5
12/31/2016	MWC-4	Iron	0.94	0.3
12/31/2016	MWC-4	pH	5.16	6.5-8.5
12/31/2016	MWC-3w	Iron	0.83	0.3
12/31/2016	MWC-3w	pH	5.2	6.5-8.5
03/31/2017	MWC-4	Iron	0.6	0.3
03/31/2017	MWC-4	pH	3.8	6.5-8.5
03/31/2017	MWC-3w	Iron	1.3	0.3
03/31/2017	MWC-3w	pH	3.8	6.5-8.5
06/30/2017	MWC-4	Iron	0.59	0.3
06/30/2017	MWC-4	pH	4.61	6.5-8.5
06/30/2017	MWC-3w	Iron	0.87	0.3
06/30/2017	MWC-3w	pH	4.72	6.5-8.5

Additional Comments: Since all wells have a history of elevated iron and low pH levels and the background wells show the same elevated iron and low pH levels these exceedances are not considered non-compliance.

Highlands: In-Compliance

DMRs review period	From 01/01/16 to 12/31/17
Any exceedances?	Yes
All monitoring wells accessible, secured & locked?	Yes

Observation: A review of the Groundwater Monitoring Reports revealed the following exceedances:

Date	MW ID#	Parameter	Result	Limit
12/31/2017	MWC-0	Alpha Gross PA	20	15
12/31/2017	MWC-3	Radium	13.2	5.0