

Sewage Sludge Treated in Other Processes

- Class A – Alternative 4
Sewage Sludge Treated in Other Processes
- Class A – Alternative 5
Use of PFRP
- Class A – Alternative 6
Use of Process Equivalent to PFRP
- Class B – Alternative 1
Monitoring of Fecal Coliform
- Class B – Alternative 2
Use of a Process Equivalent to PFRP
- Class B – Alternative 3
Use of Processes Equivalent to PSRP

PART D: SEND OFF-SITE FOR TREATMENT OR BLENDING

- c.** Which vector attraction reduction option is met for the sewage sludge at the receiving facility?
- Option 1 – Minimum 38 percent reduction in volatile solids
 - Option 2 – Anaerobic process, with bench-scale demonstration
 - Option 3 – Aerobic process, with bench-scale demonstration
 - Option 4 – Specific oxygen uptake rate for aerobically digested sludge
 - Option 5 – Aerobic processes plus raised temperature
 - Option 6 – Raise pH to 12 and retain at 11.5
 - Option 7 – 75 percent solids with no unstabilized solids
 - Option 8 – 90 percent solids with unstabilized solids
 - None