

- b. The monthly average, other than for *E. coli*, is the arithmetic mean of values obtained for samples collected during a calendar month.
- c. The weekly average, other than for *E. coli*, is the arithmetic mean of values obtained for samples collected during a 7-day period. The week begins 12:00 midnight Saturday and ends at 12:00 midnight the following Saturday. To define a different starting time for the sampling period, the permittee must notify the EPD in writing. For reporting required by Part I.D.1. of this permit, a week that starts in one month and ends in another month shall be considered part of the second month. The permittee may calculate and report the weekly average as a 7-day moving average.
- d. *E. coli* will be reported as the geometric mean of the values for the samples collected during the time periods in I.B.1.b. and I.B.1.c.
- e. Influent monitoring: Unless otherwise specified, influent samples shall be collected before any return or recycle flows. These flows include returned activated sludge, supernatants, centrates, filtrates, and backwash.
- f. Effluent monitoring: Unless otherwise specified, effluent samples shall be collected after the final treatment process and before discharge to receiving waters.
- g. A composite sample shall consist of a minimum of 5 subsamples collected at least once every 2 hours for at least 8 hours and shall be composited proportionately to flow.
- h. Flow measurements shall be conducted using the flow measuring device(s) in accordance with the approved design of the facility. If instantaneous measurements are required, then the permittee shall have a primary flow measuring device that is correctly installed and maintained. If continuous recording measurements are required, then flow measurements must be made using continuous recording equipment. Calibration shall be maintained of the continuous recording instrumentation to $\pm 10\%$ of the actual flow.

Flow shall be measured manually to check the flow meter calibration at a frequency of once a month. If secondary flow instruments are in use and malfunction or fail to maintain calibration as required, the flow shall be computed from manual measurements or by other method(s) approved by EPD until such time as the secondary flow instrument is repaired. For facilities which utilize alternate technologies for measuring flow, the flow measurement device must be calibrated semi-annually by qualified personnel.

Records of the calibration checks shall be maintained.

- i. If secondary flow instruments malfunction or fail to maintain calibration as required in I.B.1.h., the flow shall be computed from manual measurements taken at the times specified for the collection of composite samples.
- j. Preparing a list of industrial users "not detected" when they are below the detection limit and will then be considered in compliance with the effluent limit. The detection limit will also be reported.