

B.3. LAND TREATMENT SYSTEM (SPRAYFIELDS)

a. TREATMENT REQUIREMENTS, LIMITATIONS AND MONITORING

Treatment Pond System:

The discharge shall be limited and monitored by the permittee as specified below starting on the effective date of the permit:

Parameter (units)	Discharge Limitations Monthly (Weekly) average, unless otherwise stated	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location <sup>(1)</sup>
Flow (MGD)	--	Seven Days/Week	Continuous	Effluent
January - April	0.175			
May – October	0.31			
November - December	0.175			
Five-Day Biochemical Oxygen Demand (mg/L) <sup>(2)</sup>	50	One Day/Month	Grab	Influent & Effluent
Total Suspended Solids (mg/L) <sup>(2)</sup>	90	One Day/Month	Grab	Influent & Effluent
pH (standard units), Daily Minimum & Daily Maximum	6.0-9.0	One Day/Month	Grab	Effluent

<sup>(1)</sup> Influent refers to the influent to the treatment facility  
Effluent refers to the discharge from the treatment facility to the storage pond

<sup>(2)</sup> Numerical limits only apply to effluent.