

be considered to be a permit violation. If the permittee does not receive written notification from EPD releasing it from the compliance schedule, then the permittee is required to complete all items in the schedule by the dates indicated and will be required to attain compliance with the ammonia, TP, and TN effluent limitations in Part I.B.2. within 54 months of the effective date of the permit.

All correspondences and documents shall be submitted to EPD at the address below:

Environmental Protection Division  
Wastewater Regulatory Program  
2 Martin Luther King Jr. Drive SE  
Suite 1462 East  
Atlanta, Georgia 30334

9. EFFLUENT TESTING DATA (PERMIT REISSUANCE)

The application form for next permit renewal may include effluent data requirements for parameters that are not currently included in this NPDES permit, such as:

1. Oil and grease
2. Total dissolved solids
3. Temperature
4. Metals, Cyanide, and Total Phenols (Mercury must be analyzed using EPA Method 1631E)
5. Volatiles Organic Compounds
6. Acid Extractable Compounds
7. Base-Neutral Compounds
8. Etc.

A complete list of effluent parameters needed for next permit reissuance can be found in EPA NPDES Application Form 2A. The latest version of EPA application form may be available at the following link:

<https://www.epa.gov/npdes/npdes-application-forms>

For parameters not included in this permit, test results from at least 3 samples must be summarized in the application (average and maximum). The data must be no more than 4.5-year-old at the time the renewal application is submitted.

For parameters included in this permit, test results from the last 12 months must be summarized in the application (average and maximum).

In the event the permittee chooses not to reapply for coverage under this permit, this effluent testing requirement does not apply.