

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS

Outfall #001: (Latitude-Longitude: 31.444721°, -83.478527°)

The discharge from the water pollution control plant shall be limited and monitored by the permittee as specified below:

Parameters	Discharge limitations in mg/L (kg/day) unless otherwise specified		Monitoring Requirements		
	Monthly Average	Weekly Average	Measurement Frequency	Sample Type	Sample Location
Flow (MGD)	8.0	10.0	Seven Days/Week	Continuous Recording	Effluent
Five-Day Biochemical Oxygen Demand	10.0 (303)	15.0 (379)	Five Days/Week	Composite	Influent & Effluent
Total Suspended Solids	30 (910)	45 (1,137)	Five Days/Week	Composite	Influent & Effluent
Ammonia, as N	--	--	Five Days/Week	Composite	Effluent
January – March	2.1 (63.7)	3.2 (79.6)			
April – May	0.7 (21.2)	1.1 (26.5)			
June – September	0.3 (9.1)	0.5 (11.4)			
October - December	0.4 (12.1)	0.6 (15.2)			
Fecal Coliform Bacteria (#/100 mL)	200	400	Three Days/Week	Grab	Effluent
Total residual Chlorine ⁽¹⁾	0.01	0.01	Seven Days/week	Grab	Effluent

⁽¹⁾ This is also a daily maximum limitation.

(Effluent limitations continued on the next page)