

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (CONTINUED)

Parameters	Discharge limitations in mg/L unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
pH, Minimum – Maximum (Standard Unit)	6.0 – 8.5	Seven Days/Week	Grab	Effluent
Dissolved Oxygen, Minimum	6.0	Seven Days/Week	Grab	Effluent
Total Phosphorus, as P ⁽¹⁾	Report	One Day/Month	Composite	Effluent
Ortho-Phosphate, as P ⁽¹⁾	Report	One Day/Month	Composite	Effluent
Organic Nitrogen, as N ⁽²⁾	Report	One Day/Month	Composite	Effluent
Nitrate-Nitrite, as N ⁽²⁾	Report	One Day/Month	Composite	Effluent
Total Kjeldahl Nitrogen, as N ⁽²⁾	Report	One Day/Month	Composite	Effluent
Long-Term Biochemical Oxygen Demand ⁽³⁾	Report	See Below	Composite	Effluent
Chronic Whole Effluent Toxicity (%) ⁽⁴⁾	Report NOEC	See Below	Composite	Effluent

- (1) Total Phosphorus and Ortho-Phosphate must be analyzed from the same sample.
- (2) Ammonia, Organic Nitrogen, Nitrate-Nitrite, and Total Kjeldahl Nitrogen must be analyzed or calculated from the same sample.
- (3) Refer to Part I.C.10. LONG TERM BIOCHEMICAL OXYGEN DEMAND.
- (4) Refer to Part I.C.11. CHRONIC WHOLE EFFLUENT TOXICITY.