

B.1. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (CONTINUED)

Parameters	Discharge limitations in mg/L (kg/day) unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
pH, Minimum – Maximum (Standard Unit)	6.0 – 8.5	Seven Days/Week	Grab	Effluent
Dissolved Oxygen, Minimum	6.0	Seven Days/Week	Grab	Effluent
Ortho-Phosphate, as P	Report (Report)	One Day/Month	Composite	Effluent
Total Kjeldahl Nitrogen	Report	One Day/Month	Composite	Effluent
Nitrate-Nitrite	Report	One Day/Month	Composite	Effluent
Total Recoverable Zinc ⁽¹⁾	Report	One Day/Month	Composite	Effluent
Whole Effluent Toxicity Test (%) ⁽²⁾	Report NOEC	Annually	Composite	Effluent
Long-Term Biochemical Oxygen Demand ⁽³⁾	Report	One/Five Years	Composite	Effluent
Total Hardness ⁽⁴⁾	Report	One Day/Month	Grab	Receiving Stream

¹ Refer to Part I.C.8. PRIORITY POLLUTANTS.

² Refer to Part I.C.9. CHRONIC WHOLE EFFLUENT TOXICITY

³ Refer to Part I.C.10. LONG-TERM BIOCHEMICAL OXYGEN DEMAND

⁴ Total Hardness samples shall be taken concurrently with the total recoverable metals at a frequency of one day per month and shall be sampled downstream of the NPDES discharge at Johnson Road.