

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (JANUARY - APRIL)
CONTINUED

Parameter	Discharge Limitations mg/L unless otherwise specified	Monitoring Requirements		
		Measurement Frequency	Sample Type	Sample Location
Ortho-Phosphate (as P)	Report (Report)	One Day/Month	Composite	Effluent
Total Kjeldahl Nitrogen (TKN)	Report	One Day/Month	Composite	Effluent
Nitrate-Nitrite (as N)	Report	One Day/Month	Composite	Effluent
Chronic Whole Effluent Toxicity (WET) ²	Report NOEC	Annually	Composite	Effluent
pH, Minimum – Maximum (Standard Unit)	6.0 – 8.5	Seven Days/Week	Grab	Effluent
Dissolved Oxygen, Daily Minimum	5.0	Seven Days/Week	Grab	Effluent

²Refer to Part I.C.8., CHRONIC WHOLE EFFLUENT TOXICITY