

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (MAY)

The discharge(s) from the water pollution control plant shall be limited and monitored by the permittee during the month of May for the 10 MGD design flow capacity as specified below:

Parameter	Discharge Limitations mg/L (kg/day) unless otherwise specified		Monitoring Requirements		
	Monthly Avg.	Weekly Avg.	Measurement Frequency	Sample Type	Sample Location
Flow – MGD	10.0	12.5	Seven Days/Week	Continuous Recording	Effluent
Biochemical Oxygen Demand (5-Day)	12.0 (455)	18.0 (569)	Five Days/Week	Composite	Influent & Effluent
Total Suspended Solids (TSS)	30 (1137)	45 (1422)	Five Days/Week	Composite	Influent & Effluent
Fecal Coliform Bacteria (#/100 mL)	200/100 mL	400/100 mL	Three Days/Week	Grab	Effluent
Ammonia (as N)	4.3 (163)	6.4 (204)	Five Days/Week	Composite	Effluent
Total Residual Chlorine (TRC) ¹	0.04	0.04	Seven Days/Week	Grab	Effluent
Total Phosphorus (as P)	Report (Report)	Report (Report)	Five Days/Week	Composite	Effluent

¹This is a daily maximum limitation for TRC.

(Effluent Limitations continued on the next page)