

B. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS (JUNE - DECEMBER)

The discharge(s) from the water pollution control plant shall be limited and monitored by the permittee during the months of June through December for the 8 MGD design flow capacity as specified below:

| Parameter | Discharge Limitations mg/L (kg/day) unless otherwise specified | | Monitoring Requirements | | |
|--|--|-----------------|-------------------------|----------------------|---------------------|
| | Monthly Avg. | Weekly Avg. | Measurement Frequency | Sample Type | Sample Location |
| Flow – MGD | 8.0 | 10.0 | Seven Days/Week | Continuous Recording | Effluent |
| Biochemical Oxygen Demand (5-Day) | | | | | |
| June | 7.0 (212) | 10.5 (265) | Five Days/Week | Composite | Influent & Effluent |
| July – August | 10.0 (303) | 15.0 (379) | | | |
| September – October | 4.0 (121) | 6.0 (152) | | | |
| November | 7.0 (212) | 10.5 (265) | | | |
| December | 10.0 (303) | 15.0 (379) | | | |
| Total Suspended Solids (TSS) | 30 (910) | 45 (1137) | Five Days/Week | Composite | Influent & Effluent |
| Fecal Coliform Bacteria (#/100 mL) | 200/100 mL | 400/100 mL | Three Days/Week | Grab | Effluent |
| Ammonia (as N) | 2.0 (61) | 3.0 (76) | Five Days/Week | Composite | Effluent |
| Total Residual Chlorine (TRC) ¹ | 0.018 | 0.018 | Seven Days/Week | Grab | Effluent |
| Total Phosphorus (as P) | Report (Report) | Report (Report) | Five Days/Week | Composite | Effluent |

¹This is a daily maximum limitation for TRC.

(Effluent Limitations continued on the next page)