

Summary of PFOS/PFOA Testing of Drinking Water Systems for DoD Installations - NAVY

| Summary of Testing for DoD Drinking Water Systems and Actions Taken where Results were Above the EPA LHAs ¹ | | | | | | | | | | | | |
|--|----------------------------|-----------------------------------|-------------------------------------|--|---|--|--|---|--|---|--|--|
| DoD Component | Installation | State/Territory/Overseas Location | DoD Purveyor Drinking Water Systems | | | | | Non-DoD Purveyor Drinking Water Systems | | | | |
| | | | Total Number Tested | Number that Tested above the EPA LHAs ¹ | Results (PFOS/PFOA) or Range above EPA LHAs (ppt) | Actions Taken as of August 31, 2017 ² | Actions Planned after August 31, 2017, and Timeline to Implement the Actions to Reduce PFOS/PFOA Below LHA | Total Number Tested | Number that Tested above the EPA LHAs ¹ | Results (PFOS/PFOA) or Range above EPA LHAs (ppt) | Actions Taken as of August 31, 2017 ² | Actions Planned after August 31, 2017, and Timeline to Implement the Actions to Reduce PFOS/PFOA Below LHA |
| USMC | MCB Camp Pendleton (South) | California | 1 | 1 | 77 | -One sample exceeded the PFOS/PFOA combined Health Advisories Level. -The affected reservoir was drained and replaced with water from another source. -Resampling confirmed levels below the Health Advisories Level in the current water supply and levels slightly above the Health Advisories Level in the well taken out of service. Installation will continue to monitor the system. | Installation will continue to monitor the system. | N/A | N/A | N/A | | None required |
| | | | | | | | | | | | | |

Footnotes:

1: The EPA Lifetime Health Advisories (LHAs) for PFOS and PFOA are 70 parts per trillion (individually or combined).

2: Examples of actions taken include but are not limited to: sampling and analysis, retesting, shutting down a well(s), providing alternative drinking water, adding an activated carbon filter to the well, and blending water systems.