

20. The permittee shall have all flow meters checked for accuracy once every five years within 30 days of the anniversary date of the issuance of this permit. The meters must be recalibrated if the difference between the actual flow and the meter is greater than five percent
21. The permittee shall implement and/or maintain the conservation practices selected in the Water Conservation Plan submitted to the District. Any new practices selected shall be implemented within one year from the date of permit issuance. Practices that involve scheduling methods or maintenance shall be documented. Documentation for implementation and/or maintenance shall be maintained on all practices and available upon request.
22. The permittee's water use shall be consistent with the MFL prevention or recovery strategy developed for any water body from which this permitted water use directly or indirectly withdraws or diverts water, pursuant to subsection 40B-2.301(2)(h), F.A.C.
23. The lowest quality water source, such as reclaimed water, shall be used in lieu of groundwater for industrial use at this project when technically, economically, and environmentally feasible.
24. Following the effective date of the re-evaluated Minimum Flows and Levels adopted pursuant to subsection 62-42.300(1)(e), F.A.C., this permit is subject to modification during the term of the permit, upon reasonable notice by the District to the permittee, to achieve compliance with any approved MFL recovery or prevention strategy for the Lower Santa Fe River, Ichetucknee River, and Associated Priority Springs. Nothing herein shall be construed to alter the District's authority to modify a permit under circumstances not addressed in this condition.
25. The permittee is authorized to withdraw a maximum of 1.9500 mgd of groundwater for industrial use. Daily allocations are calculated on an average annual basis.