

GORNTO PUMP STATION PM

Version: 1, Dec 2019

SITE

Inspect asphalt condition.

Inspect grounds. Cut grass/kill weeds as required.

Inspect fencing and gate; ensure correct operation of gate (full swing)

Ensure all debris removed from site

Ensure that all required signage has been installed (incl. Pump Station I.D. sign)

ODOR CONTROL UNIT

Inspect outside of unit for leaks and condition. Odor of H₂S should be minimal from air discharge.

Inspect nutrient tank for water level and add 5 quarts of liquid Miracle Grow to a full tank of water.

Verify proper nutrient tank pump operation. It cycles approximately once every 15 minutes.

Verify condition of fan. No loud or unusual noises.

WETWELL

Visual check of wet well.

Check proper operation of aluminum hatch.

Are the floats hanging free and clear of rags or grease?

Ensure confined space signs/decals are installed and readable.

Inspect condition and no leaks of discharge piping.

Inspect paint condition used on piping.

Inspect grating platform and supports.