

	Operationally check generator weekly.
	Verify no alarms on generator control panel.
	Verify generator controller set to automatic.
	Verify no oil, fuel, or coolant leaks from generator.
	Verify battery charger is functioning properly.

WETWELL

	Visual check of wet well.
	Check proper operation of aluminum hatch.
	Are the floats hanging free and clear of rags or grease?
	Ensure confined space signs/decals are installed and readable.
	Inspect condition and no leaks of discharge piping.
	Inspect paint condition used on piping.
	Inspect grating platform and supports.
	Inspect for excessive grease or floating debris in wet well. Schedule for cleaning if required.