REMER PUMP STATION INSPECTION CHECKLIST

Version: 1, Dec 2019

SITE

Inspect asphalt condition.
Inspect grounds. Cut grass/kill weeds as required.
Inspect fencing and gate; ensure correct operation of gate (full swing)
Ensure all debris removed from site
Ensure that all required signage has been installed (incl. Pump Station I.D. sign)

ODOR CONTROL UNIT

Inspect outside of unit for leaks and condition. Odor of H2S should be minimal from air discharge.
Inspect nutrient tank for water level and add 5 quarts of liquid Miracle Grow to a full tank of water.
Verify proper nutrient tank pump operation. It cycles approximately once every 15 minutes.
Verify condition of fan. No loud or unusual noises.

GENERATOR

Inspect fuel tank for external leaks.
Verify adequate fuel level. Notify Tom Hess if less than ¾ full or 26" of fuel in the tank. Fuel level dip stick is stored in generator enclosure.
Verify no unusual odors inside generator enclosure: electrical burning, fuel, coolant, etc.
Verify generator main breaker is closed.
Verify no alarms on generator control panel at generator.
Verify generator switches are set to automatic at generator.
Verify no oil, fuel, or coolant leaks from generator.
Verify Racor fuel filters show clear red fuel and no water or debris.
Verify battery charger is functioning properly.