

CITY OF VALDOSTA

Drain water from water separators/filter housings as required. If water/contamination is noted, generate a new task on this work order in CMMS. OK Not OK

7. Fuel Quantity: Verify external fuel tank levels are maintained approximately 90% full. If fuel is required, notify plant superintendent. Record in-tank water and fuel level. OK Not OK

Tank 1 Fuel Quant: _____ Gal. Water: _____ Gal

Tank 2 Fuel Quant: _____ Gal. Water: _____ Gal

8. Battery Charger: Verify battery charger is operating properly. OK Not OK

9. Batteries: Verify properly serviced. Add only distilled water if electrolyte is low. OK Not OK

10. Electrical: Verify all connections, wiring, and conduit is secure and not damaged. OK Not OK

11. Generator: Inspect. OK Not OK

12. Coolant: Verify level is approximately midway in sight gage on coolant tank. If additional coolant is required, use only CAT- ELC (extended life coolant). Use of other coolant formulas will shorten the 6 year life of the CAT-ELC. OK Not

OK

13. Radiator: Inspect for dirt/contamination buildup. Verify no leaks. OK Not OK

14. Engine oil: Verify full on dipstick. If oil is required, use only SAE 15w-40 motor oil rated for diesel service. OK Not OK

15. Verify no abnormal noises/indications if system is operating. Operate engine for one hour minimum - if exercising genset. Annotate operating parameters in Daily Engine Log. OK Not OK