

16. Utilize the data provided by creek crossing inspections to prioritize the rehabilitation or re-routing of creek crossings based on stability and accessibility to reduce I/I, with the highest priority being given to the least stable. Submit a rehabilitation schedule including the above information to the Division by March 30, 2021, to become part of this Order upon approval.
17. Complete all three (3) high priority sewer line rehabilitation projects as described in Table D-9 of the Respondent's Utilities Department's 5-Year Capital Improvement Plan (Attachment G), previously known as the SEP, within thirty (30) days of the execution date of this Order. Upon completion of a comprehensive I/I project utilizing manhole level monitoring technology, evaluate, prioritize, and/or modify the need to complete the five (5) second phase/follow-on projects and submit a modified schedule to the Division for approval by the end of June 2021.
18. Complete the installation of fixed generators and/or backup pumps at the remaining 18 lift stations which do not have backups by the end of September 2023, purchasing generators and/or backup pumps at a rate of at least 6 per year.
19. Within thirty (30) days of the semiannual periods ending June 30 and December 31 of each year, submit a semi-annual progress report for all above conditions until the Division concurs on their completion, as well as the data required in Condition 10 above.

Addresses. Correspondence and other submissions to be made to the Division shall be addressed to: Watershed Compliance Program, Georgia Environmental Protection Division, 2 MLK Jr. Drive, SE, Suite 1152, Atlanta, Georgia, 30334.