

Will the use cause harm to the water resources of the area that include water quality impacts to the water source resulting from the withdrawal or diversion, water quality impacts from dewatering discharge to receiving waters, saline water intrusion or harmful upcoming, hydrologic alterations to natural systems, including wetlands or other surface waters, or other harmful hydrologic alterations to the water resources of the area?
[ref. 40B-2.301(2)(g)]

No. Project withdrawals were modeled and showed a simulated Upper Floridan aquifer drawdown of less than 0.5 foot at the project wetlands. Additionally, staff inspected project wetlands and springs and determined the use will not cause harm to the water resources of the area.

Is the use in accordance with any minimum flow or level and implementation strategy established pursuant to Sections 373.042 and 373.0421, F.S.?
[ref. 40B-2.301(2)(h)]

Yes. The proposed withdrawals are in accordance with MFLs and MFL recovery strategies pursuant to Chapters 62-42 and 40B-8, F.A.C.; and Emergency Rule 40BER17-01. Additionally, no Outstanding Florida Spring (OFS) has an estimated cumulative flow decline of 9.9% as a result of the proposed withdrawals.

Will the project use water reserved pursuant to subsection 373.223(4), F.S.?
[ref. 40B-2.301(2)(i)]

No. The project will not use water reserved by the Governing Board pursuant to subsection 373.223(4), F.S.

WITHDRAWAL POINT INFORMATION:

Site Name: Seven Springs Water Company

Well Details						
District ID	Station Name	Casing Diameter (inches)	Capacity (GPM)	Source Name	Status	Use Type
135840	P-1	10	600	FAS - Upper Floridan Aquifer	Active	Beverage Processing
135841	P-2	10	600	FAS - Upper Floridan Aquifer	Active	Beverage Processing
138124	P-3	10		FAS - Upper Floridan Aquifer	Proposed	Beverage Processing