

**Table 3-1. Facility-Wide Potential Emissions**

<b>Pollutant</b>	<b>Potential Emissions Without Fugitives (tpy)</b>	<b>PSD Major Source</b>		<b>Potential Emissions Including Fugitives (tpy)</b>	<b>Title V Major Source</b>	
		<b>Threshold (tpy)</b>	<b>Above Threshold?</b>		<b>Threshold (tpy)</b>	<b>Above Threshold ?</b>
Filterable PM	70.81	250	No	70.98	100	No
Total PM <sub>10</sub>	100.09	250	No	100.17	100	Yes
Total PM <sub>2.5</sub>	100.08	250	No	100.09	100	Yes
NO <sub>x</sub>	249.48	250	No	249.48	100	Yes
CO	207.78	250	No	207.78	100	Yes
SO <sub>2</sub>	0.25	250	No	0.25	100	No
VOC	216.22	250	No	216.22	100	Yes
CO <sub>2</sub> e	35,853	75,000	No	35,853	N/A	No
Total HAP	8.11	N/A	No	8.11	25	No
Individual HAP*	2.88	N/A	No	2.88	10	No

\* The maximum individual HAP is Formaldehyde