

FP1	FP1	CO	<2.00	2.00	<0.50	0.50	AP-42
		NOx	<9.30	9.30	<2.33	2.33	AP-42
		Filterable PM	<0.66	0.66	<0.17	0.17	AP-42
		Total PM10	<0.66	0.66	<0.17	0.17	AP-42
		Total PM2.5	<0.66	0.66	<0.17	0.17	AP-42
		SO2	<0.62	0.62	<0.15	0.15	AP-42
		VOC	<0.74	0.74	<0.19	0.19	AP-42
		CO2e	<346.18	346.18	<86.54	86.54	AP-42
		Total HAP	<1.36E-02	1.36E-02	<3.39E-03	3.39E-03	AP-42
		Max Individual HAP (Formaldehyde)	<2.48E-03	2.48E-03	<6.20E-04	6.20E-04	AP-42