

W0961	1833 Norman Dr	Fair	8''	Manhole 8'' pipe in and out, also 8'' pipe coming in. It is precast it is 7 1/2 ft. down. Manhole lid is 23'', No odor from this manhole ring and cover is good. Flow is going south its slow. It's in the turning lane asphalt.
W0419	2401 N Patterson St	Fair	12'' PVC Pipe	13ft Precast Manhole, 24''PVC main in and out flowing west, 8''PVC coming into manhole, No steps broken, located in grass, no odor and flow is heavy.
W3848 A	607 Charlton St	Poor	8''	6ft deep brick manhole, ring and cover fair, no missing brick, 22'' lid, no odor, dead end manhole, location asphalt.
W3242 B	607 Charlton St	Poor	8''	Brick, lid is 24'', No odor dead end manhole, location is asphalt as well about 5ft deep.
W3270	1113 N Oak St	Fair	8''	The address on the list is 1205 N Oak st but the manhole comes up as the 1113 n oak st. The deep of the manhole is 5ft, brick and no problems to the eye. It was three 8'' lines running into the manhole.
M0207	137 Blanchard St	Poor	20'' Clay pipe	15ft deep precast manhole, 32'' lid. Signs of wear from H2S, several leaks thought wall and joints of barrel, heavy flow, appears to be brick channel.
M0206	125 Blanchard St	Poor	20''clay pipe	16.2ft deep precast manhole, 32'' lid. Possible 6'' service line coming in, leaks throughout the barrel, and signs of H2S, loose bricks are missing from the brick channel heavy flow, replace ring and cover.
M1561	813 S Lee st	Poor	8''	Manhole needs lining bad, water infiltration around brick inside manhole.