

9. Report prepared by independent qualified person that evaluates capability and preparedness of fire departments in the vicinity of the proposed facility who would respond to a release of LNG or fire involving LNG, detailing any deficiencies with cost estimate for remedying
10. Proof of liability insurance covering proposed LNG operations
11. Written listing of applicable NFPA (National Fire Protection Association) requirements
12. Maps of floodplains
13. Such other information as FDEP determines is necessary to approve or deny Permit request.

Criteria for Siting and Operations of Facilities:

1. All LNG facilities must comply with the requirements of the provisions of the current edition of NFPA 59A Standard for the Production, Storage, and Handling of LNG.
2. Transfers of LNG to trucks or rail cars must also comply with the applicable provisions of the October 1, 2013, edition of the United States Department of Transportation's Pipeline Safety Regulations, 49 CFR Part 193, Subchapter D.
3. Facilities that transfer LNG to and from marine vessels shall be designed, built and operated in accordance with 49 CFR Part 193, Subchapter D and/or the July 1, 2013, edition of the United States Coast Guard's Navigation and Navigable Waters Regulations, 33 CFR Part 127, as applicable.
4. FDEP will determine if the information provided indicates need for additional training, personnel, or equipment to enable local fire departments to respond effectively to any release or fire involving LNG at the facility. If additional training, personnel, or equipment is needed, it shall be provided by the applicant before beginning operation of the facility.