

Bradley Eyre

From: Basilio, Eddy <Edwina.Basilio@dnr.ga.gov>
Sent: Tuesday, July 11, 2023 8:11 AM
To: Bradley Eyre
Subject: RE: Sewerage Spill Notification - Knights Creek Sanitary Sewer Trunk Line

CAUTION: This email originated from outside the City of Valdosta. Maintain caution when opening external links/attachments

Thank you for this information.

In the future, please let us know once you are aware of the spill, even if it is still ongoing. This allows us to know about the spill as it is occurring and also helps us inform citizens if we receive complaints/questions.

I will be on the lookout for the final volume.

Also, when can we be expecting the review of the proposed Consent Order back from the City?


Thank you,
Eddy Basilio

From: Bradley Eyre <beyre@valdostacity.com>
Sent: Monday, July 10, 2023 5:37 PM
To: Basilio, Eddy <Edwina.Basilio@dnr.ga.gov>
Subject: Sewerage Spill Notification - Knights Creek Sanitary Sewer Trunk Line
Importance: High

CAUTION: This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Ms. Basilio, I regret to inform you that we had a spill incident beginning Thursday June 6th of last week and ending the early morning hours of Sunday June 9th. The contractors bypass pump operation was down for part of the afternoon/evening of June 6th and the better part of June 7th causing the overflow in the area of the previous spill at a downstream MH No. M0222 - See attached for reference. We are calculating spill amount and will have you a figure to discuss tomorrow AM,

Bradley L. Eyre, SSGB
Director of Utilities



City of Valdosta Utilities Department
1016 Myrtle Street | P.O. Box 1125
Valdosta, GA 31603-1125 | p 229.259.3592