

Cooling Tower Emission Summary
Arglass Yamamura, LLC.
Valdosta Gerorgia

- A: **Two (2) Open Circuit Non-Contact Cooling Towers of process water system; Concept one operating one standby**
 Number of Cooling Towers in Operation 1 and an additional one on standby
 One Cooling Tower Water Circulating Rate 370 cubic meter/hr/cooling tower at 5000kW cooling capacity
 6.2 cubic meter/min/cooling tower
 1,629 gal/min/cooling tower
 97,744 gal/hr/cooling tower

Operating Amount per Cooling Tower		Operating Time
Amount Processed	Units	Hours
856,234,513	Gallons/yr	8760

Air Contaminant	Emission Factors per Cooling Tower (lb/hr)	PTE (ton/yr/tower)	PTE from Operating Towers (ton/yr)
PM-10	0.489	2.14	2.14
PM-2.5	0.489	2.14	2.14
PM	0.489	2.14	2.14
VOC	0.0163	0.07	0.07

Emissions Calculations per Cooling Tower			
Average Circulating Water Flow Rate	97,744	gal/hr/cooling tower	@88 degrees F = 31°C
Average Annual Solid Concentration in water	3,000	ppmv	
Average Annual VOC Concentration in water	100.0	ppmv	
	0.020%	AP-42 Table 13.4-1 for induced draft drift in cooling towers	
Drift Volume	19.55	gal/hr/cooling tower	
Water Density	8.3453	lb/gal	
Drift Mass	163.14	lb/hr/cooling tower	
	PM/PM10/PM2.5	0.4894	lb/hr based on 3,000 ppmv of total solids in cooling water
	VOC	0.0163	lb/hr based 100 ppmv of VOCs in cooling water
<u>Methodology</u>			
PM: 97,744 gal/hr x 0.02% drift x 3000 ppm ÷ 1,000,000 = 0.4849 lb/hr of PM			
VOC: 97,744 gal/hr x 0.02% drift x 100 ppm ÷ 1,000,000 = 0.0163 lb/hr of VOC			