## Cooling Tower Emission Summary Arglass Yamamura, LLC. Valdosta Gerorgia

## B: Four (4) Closed Circuit Non-Contact Cooling Towers from cooling water system; Concept four operating one standby; 5 installed

Number of Cooling Towers in Operation

4 and an additional one on standby

One Cooling Tower Water Circulation Rate

195 cubic meter/hr/cooling tower

3.25 cubic meter/min/cooling tower

859 gal/min/cooling tower

51,540 gal/hr/cooling tower

Operating Amount per Cooling Tower		<b>Operating Time</b>
	Units	Hours
451,490,400	Gallons/yr	8760

Air Contaminant	<b>Emission Factors per</b>	PTE	PTE from Operating
	Cooling Tower	(ton/yr/tower)	Towers
	(1b/hr)		(ton/yr)
PM-10	0.26	1.13	4.52
PM-2.5	0.26	1.13	4.52
PM	0.26	1.13	4.52
VOC	0.009	0.0377	0.15

Emission Calculation	ons per Cooling Tower			
Water Ciruclation R	Rate	51,540	gal/hr/cooling tower @88 degrees F = 31°C	
Average Annual Solid Concentration in water		3,000	ppm	
Average Annual VOC Concentration in water		100.0	ppm	
		0.02%	AP-42 Table 13.4-1 for induced draft drift in cooling towers	
Drift Volume		10.31	gal/hr/cooling tower	
Water Density 8.3453		8.3453	lb/gal	
Drift Mass		86.02	lb/hr/cooling tower	
	PM/PM10/PM2.5	0.2581	lb/hr based on 3,000 ppm of total solids in cooling water	
	VOC	0.0086	lb/hr based on 100 ppm of VOCs in cooling water	
<u>Methodology</u>				

PM: 51,540 gal/hr x 0.02% drift x 3000 ppm ÷ 1,000,000 = 0.2581 lb/hr of PM VOC: 51,540 gal/hr x 0.02% drift x 100 ppm ÷ 1,000,000 = 0.0086 lb/hr of VOC

Page C-22