

Emissions Summary
Arglass Yamamura, LLC
Valdosta, Georgia

One (1) Kohler 50REOZK 64kVa (51 eKW) Emergency Generator

Inputs

Description	Value	Units	Notes
Annual Operating Hours	500	hrs/yr	1
Engine Rating	86	bhp	
Sulfur Content in Diesel Fuel	15	ppm	2

Emissions Summary

Pollutant	Hourly Emission Rate (lb/hr)	Annual Emission Rate (tpy)
Filterable PM	0.19	0.05
PM ₁₀	0.19	0.05
PM _{2.5}	0.19	0.05
NO _x	1.06	0.27
CO	0.70	0.18
SO ₂	0.18	0.04
VOC	0.12	0.03
CO ₂ e	99.24	24.81
Total HAP	0.00	0.001