

**ATTACHMENT A**

City of Valdosta

Reported Spills of Raw Sewage into Waters of the State

September 1, 2022- February 28, 2023

NPDES Permit Nos. GA0020222 and GA0033235

Reported Spills of Raw Sewage into Waters of the State

<b>No.</b>	<b>Date Spill Occurred</b>	<b>Location of Spill</b>	<b>Volume (gallons)</b>	<b>Waterway Impacted</b>	<b>Cause</b>
1	2022-09-23	Buena Vista Dr	1,250	Sheri Lake Tributary	Grease
2	2022-10-13	2501 Buena Vista Cir	110	Sheri Lake	Debris
3	2023-02-08	1700 River St	1,170	Hightower Creek	Separated Sewer Line
4	2023-02-15	1810 E Park Ave	672,250	Knights Creek	Collapsed Sewer Line
5	2023-02-20	1810 E Park Ave	171,750	Knights Creek	Bypass Installation
6	2023-02-22	1810 E Park Ave	119,000	Knights Creek	Bypass Installation and Sediment Blockages