

**ATTACHMENT B**

City of Valdosta

Permit Limit Violations- Mud Creek WPCP

September 1, 2022- February 28, 2022

NPDES Permit No. GA0020222

<b>No.</b>	<b>DMR Month</b>	<b>Violation</b>	<b>Reported</b>	<b>Permitted</b>
1	Sept 2022	Ammonia Weekly Avg Load	26.0 kg/d	<=22.9 kg/d
2	Sept 2022	Ammonia Weekly Avg Conc	2.72 mg/L	<=2.25 mg/L
3	Jan 2023	Ammonia Weekly Avg Load	101.4 kg/d	<=22.9 kg/d
4	Jan 2023	Ammonia Weekly Avg Conc	11.9 mg/L	<=2.25 mg/L
5	Feb 2023	Ammonia Weekly Avg Load	48.0 kg/d	<=22.9 kg/d
6	Feb 2023	Ammonia Weekly Avg Conc	4.4 mg/L	<=2.25 mg/L