

ATTACHMENT E

City of Valdosta

Permit Limit Violations- Withlacoochee WPCP

September 1, 2022- February 28, 2022

NPDES Permit No. GA0033235

No.	DMR Month	Violation	Reported	Permitted
1	Sept 2022	BOD Monthly Avg Conc	7.3 mg/L	<=4.0 mg/L
2	Sept 2022	BOD Weekly Avg Conc	8.5 mg/L	<=6.0 mg/L
3	Oct 2022	BOD Monthly Avg Load	149.1 kg/d	<=121.0 kg/d
4	Oct 2022	BOD Weekly Avg Load	197.2 kg/d	<=152.0 kg/d
5	Oct 2022	BOD Monthly Avg Conc	10.6 mg/L	<=4.0 mg/L
6	Oct 2022	BOD Weekly Avg Conc	14.1 mg/L	<=6.0 mg/L