

Emergency Event:	WW-3 WASTEWATER PUMP STATION FAILURE
Emergency Trigger:	<ul style="list-style-type: none"> • SCADA Alarm • Power Outage • Loss of flow to WPCP • Visible evidence of leaking wastewater • Public complaint
Risks:	<ul style="list-style-type: none"> • Loss of flow to WPCP • Possible Sanitary Sewer Overflow (SSO)/Spill • Contamination / Health • Environmental / Property Damage

<p>Actions Required:</p> <ul style="list-style-type: none"> • Investigate extent and cause of failure • Make necessary repairs utilizing approved methods and procedures • If necessary, implement temporary bypassing. • If failure results in sewage overflow/spill, see procedures in SOP: Emergency Response to Sanitary Sewer Overflow/Spill
<p>Internal Contacts:</p> <ul style="list-style-type: none"> • Utilities Director (ER Lead) • Asst. Utilities Director (Alternate ER Lead) • ER/Assessment Team • City Engineer • Public Information Officer • Central Warehouse
<p>External Contacts:</p> <p>EPD</p> <p>Affected Customers</p>
<p>Follow Up Actions Required:</p> <ul style="list-style-type: none"> • Update maintenance records with details of the actions. • Written report. • Written report to EPD, if necessary.