

Emergency Event:	WW-5 VANDALISM OF WASTEWATER SYSTEM
Emergency Trigger:	<ul style="list-style-type: none"> • Any vandalism to any component of the wastewater system: WPCP, Lift Station, or manhole/sewer pipe.
Risks:	<ul style="list-style-type: none"> • Operation • Contamination

<p>Actions Required:</p> <ul style="list-style-type: none"> • If criminal activity is suspected, contact City Police Department • Determine if contamination may have occurred in wastewater system • If potential contamination, follow Suspected Contaminated Wastewater Procedures • Make necessary repairs where needed utilizing approved methods and procedures
<p>Discretionary Actions: Contact GBI/FBI if terrorist activity is suspected</p>
<p>Internal Contacts:</p> <ul style="list-style-type: none"> • Utilities Director (ER Lead) • Asst. Utilities Director (Alternate ER Lead) • City Manager/Asst. City Manager • Police Department • Fire Department • Public Information Officer (Media)
<p>External Contacts:</p> <ul style="list-style-type: none"> • EPD
<p>Follow Up Actions Required:</p> <ul style="list-style-type: none"> • Detailed Written report (internal to City) • Written report to external agencies (EPD), if required