

UTILITIES DEPARTMENT

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Asst. Director of Utilities

[Jason Barnes](#)



SPILL REPORT TO EPD

TIME/DATE OF MINOR SPILL: 12/2/23: 1400-1500

REPORT SUBMITTED: 12/4/23.

LOCATION OF SPILL: 2100 Block of Pin Oak Circle- Valdosta, GA

CAUSE OF SPILL: Blockage of gravity sewer line- Asphalt debris and rags

ESTIMATED VOLUME DISCHARGED: 6300

RECEIVING WATERS: Withlacoochee River

SERVICE BASIN AFFECTED: Suwanee River Basin

WWTP SERVICE AREA NPDES PERMIT: GA0033235

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: : Obstruction removed. Area sanitized with Lime and other cleaners.

SPILL STATUS: Stopped

SIGNS POSTED: Yes

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: : Camera Line for other obstructions. Jetting Line and other preventive maintenance.

DATE STREAM MONITORING INITIATED: N/A

DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: Yes

REPORT SUBMITTED BY: Joseph Gangler