

UTILITIES DEPARTMENT

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



SPILL REPORT TO EPD

TIME/DATE OF MINOR SPILL: 0800-1130 On 11/7/2024

REPORT SUBMITTED: 11/11/2024.

LOCATION OF SPILL: 1413 Williams Street 30.84767823583334, -83.28363401921618

CAUSE OF SPILL: Act of God/Hydraulic Overflow- High Volume Rain in short time

ESTIMATED VOLUME DISCHARGED: 4000-5000 Gallons

RECEIVING WATERS: Withlacoochee River (Via One Mile Branch and flooding)

SERVICE BASIN AFFECTED: Suwanee River Basin

WWTP SERVICE AREA NPDES PERMIT: GA0033235

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Area Sanitized.

SPILL STATUS: Stopped

SIGNS POSTED: Yes

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: Act of God/Hydraulic Overflow- High Volume Rain in short time period- Infrastructure being updated.

DATE STREAM MONITORING INITIATED: N/A

DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: 11/8/24

REPORT SUBMITTED BY: Joseph Gangler