

**UTILITIES DEPARTMENT**

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



**SPILL REPORT TO EPD**

**TIME/DATE OF MINOR SPILL:** Start:11/26/2024(1200)- End11/27/2024 (1300)

**REPORT SUBMITTED:** 12/2/2024

**LOCATION OF SPILL:** 2426 Meadowbrook Drive 30.864354736215617, -83.31398074906407

**CAUSE OF SPILL:** Unknown: debris or possible collapse

**ESTIMATED VOLUME DISCHARGED:** 1000-2000 Gallons

**RECEIVING WATERS:** Withlacoochee River (SSO enters Two Mile Branch which merges with Sugar Creek and then Withlacoochee River).

**SERVICE BASIN AFFECTED:** Suwanee River Basin

**WWTP SERVICE AREA NPDES PERMIT:** GA0033235

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:** Bypass pumps put into place until blockage could be cleared or line repaired. Area sanitized.

**SPILL STATUS:** Stopped

**SIGNS POSTED:** Yes

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:** Line will be monitored by camera for any other potential obstructions and debris. System part of ongoing infrastructure upgrades and repair.

**DATE STREAM MONITORING INITIATED:** N/A

**DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** 12/2/2024

**REPORT SUBMITTED BY:** Joseph Gangler