

UTILITIES DEPARTMENT

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



MAJOR SPILL REPORT TO EPD

TIME/DATE OF MAJOR SPILL: 2030 11/7/24--- 1200 11/10/24

REPORT SUBMITTED: 11/11/2024.

LOCATION OF SPILL: 318 Wetherington Lane - 30.81946332214432, -83.35612365838652

CAUSE OF SPILL: Act of God/Hydraulic Overflow- High Volume Rain in short time Overload of both EQ Basins

ESTIMATED VOLUME DISCHARGED: 7,200,00 Gallons

RECEIVING WATERS: Withlacoochee River (Via Spring Branch and flooding)

SERVICE BASIN AFFECTED: Suwanee River Basin

WWTP SERVICE AREA NPDES PERMIT: GA0033235

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS: Area Sanitized.

SPILL STATUS: Stopped

SIGNS POSTED: Yes

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL: Act of God/Hydraulic Overflow- High Volume Rain in short time period- Infrastructure being updated. Plant being reviewed for upgrades.

DATE STREAM MONITORING INITIATED: N/A

DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED: 11/8/24

REPORT SUBMITTED BY: Joseph Gangler