

that the Respondent publish a Public Notice in accordance with the Act and Rules and submit certification to EPD of the same; and

WHEREAS, on December 23, 2024, the Respondent sent the EPD the Public Notice and Certification of Public Notice requested by EPD; and

WHEREAS, upon execution by the Director this Consent Order shall replace and supersede all prior Consent Orders regarding the System; and

Alleged Violations

WHEREAS, during reviews of sample analysis results in the Safe Drinking Water Information System, the EPD determined that the Respondent's System had Total Trihalomethanes (TTHM) levels which exceeded the Maximum Contaminant Level of 0.080 milligrams per liter (mg/L), from the third quarter of 2019 to the fourth quarter of 2024 compliance periods; and

WHEREAS, during reviews of sample analysis results in the Safe Drinking Water Information System, the EPD determined that the Respondent's System had Haloacetic Acid (HAA5) levels which exceeded the Maximum Contaminant Level of 0.060 milligrams per liter (mg/L), from the third quarter of 2019 to the fourth quarter of 2024 compliance periods; and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2019 at sampling point 501 was 0.062 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2019 at sampling point 502 was 0.068 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2019 at sampling point 502 was 0.088 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2019 at sampling point 501 was 0.080 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2019 at sampling point 502 was 0.101 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2019 at sampling point 501 was 0.092 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2019 at sampling point 502 was 0.126 mg/L, in violation of Rule 391-3-5-.18(7)(a); and