

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2020 at sampling point 502 was 0.167 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2020 at sampling point 501 was 0.183 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2020 at sampling point 502 was 0.176 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2020 at sampling point 501 was 0.192 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2020 at sampling point 502 was 0.169 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the first quarter of 2021 at sampling point 501 was 0.202 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the first quarter of 2021 at sampling point 502 was 0.196 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the first quarter of 2021 at sampling point 501 was 0.187 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the first quarter of 2021 at sampling point 502 was 0.175 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the second quarter of 2021 at sampling point 501 was 0.217 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the second quarter of 2021 at sampling point 502 was 0.199 mg/L, in violation of Rule 391-3-5-.18(7)(a); and