

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the second quarter of 2021 at sampling point 501 was 0.188 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the second quarter of 2021 at sampling point 502 was 0.170 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2021 at sampling point 501 was 0.223 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2021 at sampling point 502 was 0.189 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2021 at sampling point 501 was 0.169 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2021 at sampling point 502 was 0.150 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2021 at sampling point 501 was 0.203 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the fourth quarter of 2021 at sampling point 502 was 0.163 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2021 at sampling point 501 was 0.148 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for TTHM detected at the System during the fourth quarter of 2021 at sampling point 502 was 0.129 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

WHEREAS, the Locational Running Annual Average for HAA5 detected at the System during the first quarter of 2022 at sampling point 501 was 0.199 mg/L, in violation of Rule 391-3-5-.18(7)(a); and