

**WHEREAS**, the Locational Running Annual Average for HAA5 detected at the System during the first quarter of 2022 at sampling point 502 was 0.170 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the first quarter of 2022 at sampling point 501 was 0.173 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the first quarter of 2022 at sampling point 502 was 0.140 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for HAA5 detected at the System during the second quarter of 2022 at sampling point 501 was 0.211 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for HAA5 detected at the System during the second quarter of 2022 at sampling point 502 was 0.180 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the second quarter of 2022 at sampling point 501 was 0.198 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the second quarter of 2022 at sampling point 502 was 0.153 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2022 at sampling point 501 was 0.218 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for HAA5 detected at the System during the third quarter of 2022 at sampling point 502 was 0.182 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2022 at sampling point 501 was 0.220 mg/L, in violation of Rule 391-3-5-.18(7)(a); and

**WHEREAS**, the Locational Running Annual Average for TTHM detected at the System during the third quarter of 2022 at sampling point 502 was 0.172 mg/L, in violation of Rule 391-3-5-.18(7)(a); and