



GEORGIA

DEPARTMENT OF NATURAL RESOURCES

ENVIRONMENTAL PROTECTION DIVISION

Richard E. Dunn, Director

Southwest District
2024 Newton Road
Albany, Georgia 31701
229-430-4144

April 26, 2019

Honorable Brenda Exum, Mayor
City of Ray City
Post Office Box 128
Ray City, GA 31645

RE: Letter of Non-Compliance
City of Ray City Water Pollution Control Plant (WPCP)
NPDES Permit No. GA0033553
Berrien County, Georgia
Periods: March 2019

Dear Mayor Exum:

The National Pollutant Discharge Elimination System (NPDES) Permit authorizing discharge from this water pollution control facility requires that the facility monitor and report specific parameters. The Discharge Monitoring Reports (DMR's) from the facility for the referenced period has been reviewed. The discharge for the referenced period violated the effluent monitoring requirements for the Permit as follows:

<u>Reporting Period</u>	<u>Parameter</u>	<u>Permit Limitation</u>	<u>Reported Value</u>
3/03/19-3/09/19	Effluent Flow	0.125 MGD (Weekly Avg.)	0.220 MGD
3/17/19-3/23/19	Effluent Flow	0.125 MGD (Weekly Avg.)	0.134 MGD
3/1/19-3/31/19	Effluent Flow	0.10 MGD (Monthly Avg.)	0.142 MGD

Please be advised that the requested CAP and implementation schedule is in the process of being developed by the facility and will be subject to Division approval and will likely be implemented through an enforcement mechanism that may include the imposition of a monetary settlement. Should you have questions or comments concerning this correspondence, please contact this office at (229) 430-4144.

Sincerely,


Mel Taylor
Environmental Compliance Specialists

MT

C: Water Quality File - Berrien County
Mr. Brandon Rice, Certified Operator (via e-mail)