


City of Valdosta - Engineering Services Department

300 N. Lee St.
Valdosta, GA 31601
229-259-3530

Today's Date: August 20, 2021

Violation Date & Time: August 20, 2021

Case Number: 21-001

Location of Violation HWY 94/ St Augustine RD

Parcel Number: 0084C 009

Certified Mail Number: 7014 2120 0004 7059 7849

Valdosta Mall Corners

P O BOX 269

TIFTON, GA 31793

Inspection/Correction/Report

Property inspected found to be in violation of the City's Land Development Regulations for Stormwater. Detention facility's outlet structure and pipe have failed and no longer functions as designed. Parking lot drainage pipe has failed at catch basin causing runoff to washout pavement. See attached Photos

LDR Section 310-51 Long-term Maintenance Inspection of Stormwater Facilities and Practices

(B) Where no maintenance agreement has been recorded, it shall be the responsibility of the property owner(s) to maintain the operational characteristics of any facility (detention/retention pond, swale, gulley, inlet, outlet and/or pipe) constructed on their property for storm water management pursuant to City requirements to keep access points to the facility free of obstructions, and to keep the facility free of trash, debris, excessive vegetation, excessive sediment, and other obstacles that would pollute, contaminate or retard the flow of water through the stormwater management facility.

An engineered plan must be submitted to the City Engineer's office for approval prior to beginning work.

The failed outlet control structure, catch basin and associated failed CMP pipes must be replaced within the parking lot and storm water detention pond.

All trash and waste materials must be removed and properly disposed of.

This warning will expire on **September 23, 2021** in reference to the above mentioned violations. If the noncomplaine violations have not been corrected within the specified time frame, this case will be referred to the City Marshal's Office for legal action. Upon conviction, such person shall be punished by a fine not to exceed \$1,000 per violation or imprisonment for 60 days or both. Each act of violation and each day upon which any violation shall occur, shall constitute a separate offense.

This violation may be appealed to the City Engineer by filing a written notice of appeal within 10 days of receiving. Submit appeals to the City of Valdosta Engineering at the City Hall Annex Building, 300 N Lee Street, Valdosta, GA. If you have questions or need other assistance, call (229) 259-3530.

Sincerely,

Willie Jones

Willie Jones, Stormwater Tech