



**Mud Creek WPCP STANDARD OPERATING PROCEDURE (SOP):  
PLANT OPERATIONS/EQUIPMENT INSPECTION ROUNDS**

Issue Date: 4/2011      Revision: 2      Review Frequency: Annual

UNKNOWN CONTAMINANT IN WASTESTREAM INTO PLANT:

If during rounds operator sees, smells, or online instrumentation detects anything that is not normal for waste stream entering plant, the following procedures are followed:

- Inform Plant Superintendent and/or Assist. Supt. of issue, if after hours, follow the Emergency Callout procedure. Refer to **Mud Creek ERP, Section 3.2 Incident-Specific Response Procedures: Emergency Event: WW-4 WASTEWATER CONTAMINATION.**
- Record Date/Time and pertinent information in operators' logbook.