

Emergency Event:	WW-8 TREATMENT PLANT POWER FAILURE
Emergency Trigger:	<ul style="list-style-type: none"> • Alarms via SCADA system • Notification from Georgia Power or Colquitt EMC
Risks:	<ul style="list-style-type: none"> • Plant Operations • Spill/Contamination • NPDES violation

Actions Required:

- Assess situation and determine magnitude of interruption
- Contact Georgia Power to determine magnitude of failure
- In the event of extended power failure (as indicated by Ga. Power), prepare to run diesel generator(s) for back-up power supply.
- If failure results in sewage overflow/spill, follow procedures in SOP: Emergency Response to Sanitary Sewer Overflow/Spill

Internal Contacts:

- Utilities Director (ER Lead)
- Asst. Utilities Director (Alternate ER Lead)
- Environmental Manager
- City Manager/Asst. City Manager
- Public Information Officer
- Fire Department
- Police Department

External Contacts:

- EPD
- Health Department

Follow Up Actions Required:

- Detailed Written report (internal to City)
- Written report to external agencies (EPD), if required