

**UTILITIES DEPARTMENT**

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Asst. Director of Utilities

[Jason Barnes](#)



**SANITARY SEWER OVERFLOW (SSO) REPORT TO EPD**

**TIME/DATE OF OVERFLOW:** 12/4/2023 from 1030-1500

**REPORT SUBMITTED:** 12/4/23

**LOCATION OF OVERFLOW (GPS LOCATION):** 1800 Block E Park Avenue

**CAUSE OF OVERFLOW:** Contractor owned/operated pumps for city projects bypass were turned down for unknown reason by contractor. Allowed Infiltration and Inflow to overwhelm system.

**ESTIMATED VOLUME DISCHARGED:** 7500 gallons.

**SERVICE BASIN AFFECTED:** NA

**WWTP SERVICE AREA NPDES PERMIT:** GA00200222

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**

Central Maintenance Operators directed Contractor to increase pump speed to deal with backup. Pumps at maximum to deal with flow, no issue.

**OVERFLOW STATUS:** Stopped @1500

**SIGNS POSTED:** N/A

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:**

Contractor to be counseled on new SOPs for private pump monitoring and usage on City Bypass systems. Any other action TBD.

**DATE STREAM MONITORING INITIATED:** N/A

**DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:** N/A

**REPORT SUBMITTED BY:** Joseph Gangler