
Public Notice of Pollution - Initial Notice

no-reply@dep.state.fl.us <no-reply@dep.state.fl.us>
To: no-reply@dep.state.fl.us

Thu, Apr 25, 2024 at 10:08 AM



**FLORIDA DEPARTMENT OF
Environmental Protection**

Bob Martinez Center
2600 Blair Stone Road
Tallahassee, Florida 32399-2400

Ron DeSantis
Governor

Jeanette Nuñez
Lt. Governor

Shawn Hamilton
Secretary

Pollution Notice

Thank you for submitting a Public Notice of Pollution for a reportable Incident in compliance with Section 403.077, F.S.

All information displayed was submitted by the reporting party.

Type of Notice: Initial Report

Date of Notice: 04/25/2024

Incident Information

Name of Incident: SSO 2024-5358

State Watch Office Case Number: 2024-5358

Start of Incident: 04/24/2024 00:00

End of Incident: 04/24/2024 07:00

Incident Description: Bypass ball valve in discharge pipe vault union separated and pumped out from there. Residents in area mentioned smelling something around midnight the previous night but never reported it till maintenance showed up at 0700 and called us to report it. We were able to shut the pumps off and close a valve after the vault to isolate the station.

Wastewater Type: Untreated

Cause: Bypass

Spill Volume: 1500

Volume Recovered: 0

Waterbodies Impacted: NA

Clean-up Status: Complete

Clean-up Actions: Applied lime, Signs posted

Agencies Notified: Alachua EPD Efrain Tavarez

Incident Location