

**UTILITIES DEPARTMENT**

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



**SANITARY SEWER OVERFLOW (SSO) REPORT TO EPD**

**TIME/DATE OF OVERFLOW:** 1/14/2025 0930-1130

**REPORT SUBMITTED:** 1/14/2025

**LOCATION OF OVERFLOW (GPS LOCATION):** 110 Jackson Street 30.811026729309432, -83.2718296174818

**CAUSE OF OVERFLOW:** Obstruction from trash from local corrections facility

**ESTIMATED VOLUME DISCHARGED:** 1800 gallons.

**SERVICE BASIN AFFECTED:** NO

**WWTP SERVICE AREA NPDES PERMIT:** Mud Creek WWTP GA0020222

**CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:**

Area sanitized

**OVERFLOW STATUS:** Stopped

**SIGNS POSTED:** No

**CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:**

Line cleaned, source traced to local corrections facility. Talked to management about issue and how to be good stewards and try and prevent future problems.

**DATE STREAM MONITORING INITIATED:** N/A

**DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:**1/14/25

**REPORT SUBMITTED BY:** Joseph Gangler