

UTILITIES DEPARTMENT

PH: 229-259-3592

FAX: 229-241-8285

Emergency: 229-434-4132

Director of Utilities

[Jason Barnes](#)



SANITARY SEWER OVERFLOW (SSO) REPORT TO EPD

TIME/DATE OF OVERFLOW: 1/14/2025 0930-1130

REPORT SUBMITTED: 1/14/2025

LOCATION OF OVERFLOW (GPS LOCATION): 110 Jackson Street 30.811026729309432, -83.2718296174818

CAUSE OF OVERFLOW: Obstruction from trash from local corrections facility

ESTIMATED VOLUME DISCHARGED: 1800 gallons.

SERVICE BASIN AFFECTED: NO

WWTP SERVICE AREA NPDES PERMIT: Mud Creek WWTP GA0020222

CORRECTIVE ACTION TAKEN TO MITIGATE OR TO REDUCE ADVERSE EFFECTS:

Area sanitized

OVERFLOW STATUS: Stopped

SIGNS POSTED: No

CORRECTIVE ACTION TAKEN TO PREVENT FUTURE SPILL:

Line cleaned, source traced to local corrections facility. Talked to management about issue and how to be good stewards and try and prevent future problems.

DATE STREAM MONITORING INITIATED: N/A

DATE MEDIA / HEALTH DEPARTMENT / OTHERS NOTIFIED:1/14/25

REPORT SUBMITTED BY: Joseph Gangler